

Certificate

EC-Type-Examination

acc. to Directive 97/23/EC

Zertifikat Nr.: 01 202 642-B-12083

Name and address of the manufacturer: **Goetze KG
Armaturen
Postfach 4 48
71604 Ludwigsburg**

We hereby certify, that the type example mentioned below meets the requirements of the Directive 97/23/EC.

Tested acc. to Directive 97/23/EC: **EC-Type-Examination (Module B)**


Test report No.: 642-12-2013

Description of type example: **Safety Valve**
Design: direct-acting, spring loaded
Type: 651 m SK
Medium: provided for venting water and water mixtures from closed, intrinsically safe solar heating systems
Set Pressure: : 2 – 10 bar

Valid until: 12.04.2022

The CE marking must not be affixed and the Declaration of Conformity not be issued prior to completion of the corresponding conformity assessment procedure according to Directive 97/23/EC.

Aachen, 10.04.2012


Dipl.-Ing. Manfred Rönning



TÜV Rheinland-Certification Body for Pressure Equipment
TÜV Rheinland Industrie Service GmbH, Notified Body, ID-No. 0035
Am Grauen Stein, D-51105 Köln
Außenstelle Aachen
Krefelder Str. 225, 52070 Aachen, Tel. ++49-241/1825-870
E-Mail: service-is-mw@de.tuv.com